



INTERFACE OPTIONS

INPUTS	
No.	DESCRIPTION
35-36	REMOTE ON/OFF INTERRUPT
39-40	CUSTOM FAULT No. 1
41-42	CUSTOM FAULT No. 2
43-44	LIQUID HIGH LIMIT (STANDARD ON SERIES 11)
57-58	DAMPER END SWITCH
49-50	REHEAT/HUMIDIFIER DISABLE

OUTPUTS	
No.	DESCRIPTION
25-26	PUMP INTERLOCK
37-38	UNIT STATUS
59-60	DAMPER INTERLOCK

- RS 485 Communication for use with Modbus RTU
- Monitoring and Control System.

