



- | | | |
|--------------------------------|-------------------------------|--------------------------------------|
| 1 Compressor | 11 Access valve | 21 Glycol Cooler * |
| 2 High pressure switch | 12 Shut off valve | 23 Three-way Modulating Valve |
| 3 Low pressure switch | 13 Glycol cooled condenser | |
| 4 Rotalock valve | 14 Glycol regulating valve ** | |
| 5 Evaporator | 15 Globe valve * | — Factory Installed Refrigerant Line |
| 6 Refrigerant distributor | 16 Gate valve * | — Factory Installed Glycol Line |
| 7 Thermostatic expansion valve | 17 Orifice valve * | - - - Field Installed Glycol Line |
| 8 Free-cooling coil | 18 Check valve * | |
| 9 Sight glass | 19 Pump * | |
| 10 Filter-drier | 20 Expansion Tank * | |

* Supplied by others
 ** Standard two way water regulating valve. Optional three way water regulating valve available.