



FACTORY WIRED FACTORY INSTALLED
(FIELD INSTALLED SERIES 11 ONLY)

INTERFACE OPTIONS

INPUTS	
No.	DESCRIPTION
31-32	COMPRESSOR DISABLE
35-36	REMOTE ON/OFF INTERRUPT
39-40	CUSTOM FAULT No. 1
41-42	CUSTOM FAULT No. 2
43-44	LIQUID HIGH LIMIT (STANDARD ON SERIES 11)
57-58	DAMPER END SWITCH
49-50	REHEAT/HUMIDIFIER DISABLE
OUTPUTS	
No.	DESCRIPTION
37-38	UNIT STATUS
59-60	DAMPER INTERLOCK



UNIT CONTROL PANEL



LEGEND

- TERMINALS ON PCB
- STH TEMPERATURE & HUMIDITY SENSOR
- SW WATER DETECTOR (OPTION)
- CONNECTION TERMINAL
- FACTORY WIRING
- FIELD SUPPLIED WIRING