






CLIMATEWORX
MISSION CRITICAL CLIMATE CONTROL


SERIES 9-VERTICAL FLOOR MOUNT UPFLOW STANDARD COOLING (3+1) 'A' MOD UNIT -LH




LEFT END VIEW



FRONT ELEVATION



RIGHT END VIEW



BASE FRAME OUTLINE DETAIL - SECTION A-A

PIPING CONNECTION SIZE

MODEL NO. SUFFIX		14	16	18	20	22	*25
Liquid Refrigerant	-ODM in	5/8	5/8	5/8	5/8	5/8	-
Hot Gaseous Refrigerant	-ODM in	1 1/8	1 1/8	1 1/8	1 1/8	1 1/8	-
Hot Water	-ODM in	1	1	1 1/8	1 1/8	1 1/8	1 1/8
Steam	-ODM in	7/8	7/8	7/8	7/8	7/8	7/8
Steam Condensate	-ODM in	3/4	3/4	3/4	3/4	3/4	3/4
Humidifier Water	-ODM in	1/4	1/4	1/4	1/4	1/4	1/4
Cooling Coil Condensate	-ODM in	3/4	3/4	3/4	3/4	3/4	3/4
Chilled Water	-ODM in	1 5/8	1 5/8	2 1/8	2 1/8	2 1/8	2 1/8
Condensing Water	-ODM in	1 3/8	1 3/8	1 3/8	1 3/8	1 3/8	-
Glycol Solution	-ODM in	2 1/8	2 1/8	2 1/8	2 1/8	2 1/8	-

ODM - Outside Diameter of copper pipe in inches for soldering MPT - Male Pipe Thread *-Chilled Water Only